



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Marsh Elementary - Attales Middle School

800 Ireland Avenue
Absecon, NJ 08201

Results of Lead Analysis

Date & Time Sampled: 05/006/2017 10:00 - 10:02

Date & Time Analyzed: 05/10/2017 10:40 - 11:00

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
MSH-KC-KIT2	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwater.test.com
 NJ DEP Certification #080006

Customer: Epic Environmental Services, LLC
 Contact: James Eberts
 Address: 1930 Brown Road
 Newfield, NJ 08344
 Phone: _____ Fax: _____
 Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
065154	MSH - FB	5/16/17	1000	D	1 x 250		First Draw Lead	Field Blank
065155	MSH - KC - KIT 2	5/16/17	1002	D	1 x 250		First Draw Lead	
	MSH - KC - KIT 2 (Flush)	5/16/17	1023	D	1 x 250		Flushed Lead	
	End			D	1 x 250			
				D	1 x 250			
				D	1 x 250			
				D	1 x 250			
				D	1 x 250			
				D	1 x 250			
				D	1 x 250			

MATRIX ABBREVIATIONS: D=DIRINKING WATER A=AQUEOUS S=SOIL SL=SLUDGE GW=GROUND WATER SW=SURFACE WATER W=WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval ASAP	<input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Preserve upon Receipt Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L	<input type="checkbox"/> Yes <input type="checkbox"/> No

Sampled by: (Print) James Eberts	Received by: (Signature) <i>[Signature]</i>	Date 5/17/17	Date 5/17/17	Time 1000	Time 1000
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) <i>[Signature]</i>	Date	Date	Time	Time
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) <i>[Signature]</i>	Date	Date	Time	Time

Marsh Elementary-Attles Middle School
Excel Template for Lead Results

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
Field ID	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
1	N	P65154	South Jersey Water Test, LLC	08006	5/6/2017	10:00	SM3113B	5/10/2017	10:40	<2.00	<2.00	1	N	
2	N	P65155	South Jersey Water Test, LLC	08006	5/6/2017	10:02	SM3113B	5/10/2017	11:00	<2.00	<2.00	1	N	